

**05/21/2010**

**Amendment #1 to ITB 52659NDM Replace Fire Panel**

**QUESTIONS and ANSWERS**

1. Are there any building plans for review? Yes-Drawings and floor plans may be picked up at Lentz Clinic, 311 23 Ave. North, Nashville, TN 37203. See the guard in the lobby.
2. Are we bidding line items to code or as they are listed? Bid to code.
3. What are the work hours? Work hours are Mon-Fri 8-5. Extended hours can be arranged if needed.
4. Can the existing wiring be re-used? No-Install new wiring
5. Do employees of the contractor have to be background checked? No
6. What's the annual monitoring cost? Will Metro provide phone lines? Metro will provide phone lines. Metro has a monitoring contract with ADT. New equipment shall be universally compatible with other monitoring services.
7. What year Code should specifications meet; NFPA72, NFPA 101 Life Safety, or NFPA 70 Nat'l Electric Code? 2002 NFPA72 or later is the Metro requirement.
8. Is the community center included? Yes-The Community Center and the Clinic are to be included in this bid. The Community Center is listed as Tennant in the specifications.

**Best regards,**

**Doug Milligan**

**Metro Government Purchasing Analyst**

**615-862-6670**

## BID RESPONSE

### Firefighting & Emergency Medical Protective Garments

ITB #52520 NDM

---

#### *CONTACT INFORMATION*

In order to complete the evaluation process faster, list the name, address, phone number, fax number, and email address of the person capable of answering any questions that may arise during the evaluation process. (Please Print or Type)

Company Name: \_\_\_\_\_

Attention: \_\_\_\_\_

Address: \_\_\_\_\_

City/ST/Zip: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Itm No	Qty	Unit	Description	Unit Price	Extended Price
Prices bid below shall be firm and be the actual prices charged for these items for one (1) year from the effective date of the contract. Bidders leaving items blank shall be disqualified.					
1	250	Ea	Firefighting Pants as specified.	\$_____	\$_____
2	250	Ea	Firefighting Coats as specified.	_____	_____
3	250	Pair	Firefighting Suspenders as specified.	_____	_____
			Total Extended Price Firefighting Equipment		\$_____
4	50	Ea	Emergency Medical Pants as specified.	_____	_____
5	50	Ea	Emergency Medical Coats as specified	_____	_____
6	50	Pair	Emergency Medical Suspenders as specified.	_____	_____
			Total Extended Bid Price Medical Equipment		\$_____